

Display Energy Certificate

How efficiently is this building being used?



Department of Energy & Climate Change
3-8 Whitehall Place
LONDON
SW1A 2HH


Certificate Reference Number:
0098-9592-5110-2590-8003

This certificate indicates how much energy is being used to operate this building. The operational rating is based on meter readings of all the energy actually used in the building. It is compared to a benchmark that represents performance indicative of all buildings of this type. There is more advice on how to interpret this information on the Government's website www.communities.gov.uk/epbd.

Energy Performance Operational Rating

This tells you how efficiently energy has been used in the building. The numbers do not represent actual units of energy consumed; they represent comparative energy efficiency. 100 would be typical for this kind of building.


More energy efficient



Less energy efficient


Total CO₂ Emissions

This tells you how much carbon dioxide the building emits. It shows tonnes per year of CO₂.



Previous Operational Ratings

This tells you how efficiently energy has been used in this building over the last three accounting periods



Technical information

This tells you technical information about how energy is used in this building. Consumption data based on actual meter readings.

Main heating fuel: Natural Gas
Building Environment: Air Conditioning
Total useful floor area (m²): 10960
Asset Rating: Not available.

	Heating	Electrical
Annual Energy Use (kWh/m ² /year)	41	156
Typical Energy Use (kWh/m ² /year)	125	106
Energy from renewables	0%	0%

Administrative information

This is a Display Energy Certificate as defined in SI 2007/991 as amended.

Assessment Software: CLG, ORCalc, v3.5.1
Property Reference: 885505120000
Assessor Name: Darren Myers
Assessor Number: LCEA129289
Accreditation Scheme: CIBSE Certification Limited
Employer/Trading Name: Briar Associates
Employer/Trading Address: York House, High Street, Amblecote, DY8 4BT
Issue Date: 12-11-2010
Nominated Date: 12-11-2010
Valid Until: 11-11-2011
Related Party Disclosure: Not related to the occupier

Recommendations for improving the energy efficiency of the building are contained in the accompanying Advisory Report.